

Environment Testing America

ANALYTICAL REPORT

Eurofins QC, LLC – Horsham, PA 702 Electronic Drive Horsham, PA 19044-0962 Tel: (215)355-3900

Laboratory Job ID: 630-12809-1

Client Project/Site: Head Start - 5800 Kennedy Blvd, WNY

Revision: 1

For:

North Hudson Community Action Corp. 7611 Broadway North North Bergen, New Jersey 07047

Attn: Jay Johnson

Authorized for release by: 5/5/2021 2:18:29 PM

Erin Dougherty, Project Administrator

(215)355-3900 Erin.Dougherty@eurofinset.com

.....LINKS

Review your project results through

Total Access

Have a Question?



Visit us at:

www.eurofinsus.com/Env

The test results in this report meet all 2003 NELAC, 2009 TNI, and 2016 TNI requirements for accredited parameters, exceptions are noted in this report. This report may not be reproduced except in full, and with written approval from the laboratory. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

This report has been electronically signed and authorized by the signatory. Electronic signature is intended to be the legally binding equivalent of a traditionally handwritten signature.

Results relate only to the items tested and the sample(s) as received by the laboratory.

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

Coliform MCLs

• Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by EQC field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification #02015 VL = field staff performs tests under NJ State certification #06005 WG = field staff performs tests under NJ State certification #PA001

H = field staff performs tests under NJ NELAP certification #PA093, PA NELAP certification # 46-

05499

- · Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.
- · The report shall not be reproduced, except in full, without the written consent of the laboratory
- · All samples are collected as "grab" samples unless otherwise identified.
- · Reported results related only to the samples as tested. EQC is not responsible for sample integrity unless sampling has been performed by a member of our staff.
- EQC is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.
- Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.
- The following personnel or their deputies have approved the results of the tests performed by EQC: Nicki Smith (Environmental Chemistry) and Zachary Smith (Water Microbiology).

Erin Dougherty

Project Administrator

5/5/2021 2:18:29 PM

Case Narrative

Client: North Hudson Community Action Corp. Project/Site: Head Start - 5800 Kennedy Blvd, WNY Job ID: 630-12809-1

Job ID: 630-12809-1

Laboratory: Eurofins QC, LLC - Horsham, PA

Narrative

Job Narrative 630-12809-1

REVISION

The report being provided is a revision of the original report sent on 2/5/2021. The report (revision 1) is being revised due to The incorrect project name was listed..

Report revision history

Receipt

The samples were received on 1/25/2021 2:47 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.2°C

Metals

Method 200.8_SDWA: The reference method requires samples to be preserved to a pH of <2. The following sample(s) were received with insufficient preservation at a pH of 5: BATHROOM M-2 (630-12809-12).

No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

2

3

4

6

7

Sample Summary

Client: North Hudson Community Action Corp. Project/Site: Head Start - 5800 Kennedy Blvd, WNY

CHILDS BR B-2

630-12809-22

Job ID: 630-12809-1

630-12809-2 CLASS 11T Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-3 LADIES BR-1 Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-4 LADIES BR-2 Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-5 ADM. BR Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-6 CHILDS BR-1 Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-7 CHILDS BR-2 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-8 CHILDS BR G-1 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:51 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM M-2 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 <t< th=""><th></th><th></th><th></th><th></th><th></th><th></th></t<>						
630-12809-2 CLASS 11T Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-3 LADIES BR-1 Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-4 LADIES BR-2 Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-5 ADM. BR Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-6 CHILDS BR-1 Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-7 CHILDS BR-2 Drinking Water 01/22/21 06:30 01/25/21 14:47 630-12809-8 CHILDS BR G-1 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:30	Lab Sample ID	Client Sample ID	Matrix	Collected	Received	As
630-12809-3 LADIES BR-1 Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-4 LADIES BR-2 Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-5 ADM. BR Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-6 CHILDS BR-1 Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-7 CHILDS BR G-2 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-8 CHILDS BR G-1 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM L1 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:40	630-12809-1	CLASS 9T	Drinking Water	01/22/21 06:37	01/25/21 14:47	
630-12809-4 LADIES BR-2 Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-5 ADM. BR Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-6 CHILDS BR-1 Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-7 CHILDS BR-2 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-8 CHILDS BR G-1 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM L1 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN RINSE SINK Drinking Water 01/22/21 06:4	630-12809-2	CLASS 11T	Drinking Water	01/22/21 06:38	01/25/21 14:47	
630-12809-5 ADM. BR Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-6 CHILDS BR-1 Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-7 CHILDS BR-2 Drinking Water 01/22/21 06:43 01/25/21 14:47 630-12809-8 CHILDS BR G-1 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM M-2 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-16 KITCHEN RINSE SINK Drinking Water 01/22/21 06	630-12809-3	LADIES BR-1	Drinking Water	01/22/21 06:39	01/25/21 14:47	
630-12809-6 CHILDS BR-1 Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-7 CHILDS BR-2 Drinking Water 01/22/21 06:43 01/25/21 14:47 630-12809-8 CHILDS BR G-1 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM L1 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L2 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-16 KITCHEN RINSE SINK Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 0	630-12809-4	LADIES BR-2	Drinking Water	01/22/21 06:40	01/25/21 14:47	
630-12809-7 CHILDS BR-2 Drinking Water 01/22/21 06:43 01/25/21 14:47 630-12809-8 CHILDS BR G-1 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:51 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM L1 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L2 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN RINSE SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water	630-12809-5	ADM. BR	Drinking Water	01/22/21 06:41	01/25/21 14:47	
630-12809-8 CHILDS BR G-1 Drinking Water 01/22/21 06:50 01/25/21 14:47 630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:51 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM M-2 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/2	630-12809-6	CHILDS BR-1	Drinking Water	01/22/21 06:42	01/25/21 14:47	
630-12809-9 CHILDS BR G-2 Drinking Water 01/22/21 06:51 01/25/21 14:47 630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM M-2 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-7	CHILDS BR-2	Drinking Water	01/22/21 06:43	01/25/21 14:47	
630-12809-10 SLOP SINK Drinking Water 01/22/21 06:52 01/25/21 14:47 630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM M-2 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47 01/25/21 01/25/21 14:47 01/25/21 01/	630-12809-8	CHILDS BR G-1	Drinking Water	01/22/21 06:50	01/25/21 14:47	
630-12809-11 BATHROOM M-1 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-12 BATHROOM M-2 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-9	CHILDS BR G-2	Drinking Water	01/22/21 06:51	01/25/21 14:47	
630-12809-12 BATHROOM M-2 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-10	SLOP SINK	Drinking Water	01/22/21 06:52	01/25/21 14:47	
630-12809-13 BATHROOM L1 Drinking Water 01/22/21 06:37 01/25/21 14:47 630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-11	BATHROOM M-1	Drinking Water	01/22/21 06:35	01/25/21 14:47	
630-12809-14 BATHROOM L2 Drinking Water 01/22/21 06:38 01/25/21 14:47 630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:36 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-12	BATHROOM M-2	Drinking Water	01/22/21 06:36	01/25/21 14:47	
630-12809-15 KITCHEN PAN SINK Drinking Water 01/22/21 06:39 01/25/21 14:47 630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-13	BATHROOM L1	Drinking Water	01/22/21 06:37	01/25/21 14:47	
630-12809-16 KITCHEN HAND SINK Drinking Water 01/22/21 06:40 01/25/21 14:47 630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-14	BATHROOM L2	Drinking Water	01/22/21 06:38	01/25/21 14:47	
630-12809-17 KITCHEN RINSE SINK Drinking Water 01/22/21 06:41 01/25/21 14:47 630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-15	KITCHEN PAN SINK	Drinking Water	01/22/21 06:39	01/25/21 14:47	
630-12809-18 KITCHEN DISH WASHER SINK Drinking Water 01/22/21 06:42 01/25/21 14:47 630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-16	KITCHEN HAND SINK	Drinking Water	01/22/21 06:40	01/25/21 14:47	
630-12809-19 CLASS 41 Drinking Water 01/22/21 06:35 01/25/21 14:47 630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-17	KITCHEN RINSE SINK	Drinking Water	01/22/21 06:41	01/25/21 14:47	
630-12809-20 CLASS 7T Drinking Water 01/22/21 06:36 01/25/21 14:47	630-12809-18	KITCHEN DISH WASHER SINK	Drinking Water	01/22/21 06:42	01/25/21 14:47	
ŭ	630-12809-19	CLASS 41	Drinking Water	01/22/21 06:35	01/25/21 14:47	
630-12809-21 CHILDS BR B-1 Drinking Water 01/22/21 06:53 01/25/21 14:47	630-12809-20	CLASS 7T	Drinking Water	01/22/21 06:36	01/25/21 14:47	
	630-12809-21	CHILDS BR B-1	Drinking Water	01/22/21 06:53	01/25/21 14:47	

Drinking Water

01/22/21 06:54 01/25/21 14:47

3

Job ID: 630-12809-1

Client: North Hudson Community Action Corp. Project/Site: Head Start - 5800 Kennedy Blvd, WNY

Client Sample ID: CLASS 9T

Lab Sample ID: 630-12809-1

Matrix: Drinking Water

Date Collected: 01/22/21 06:37 Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.060		0.010	0.010	mg/L		02/04/21 12:37	1	MG7H
Lead	ND		0.0010	0.00069	mg/L		02/04/21 12:37	1	MG7H

Client Sample ID: CLASS 11T Lab Sample ID: 630-12809-2

Matrix: Drinking Water Date Collected: 01/22/21 06:38

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Copper	0.045		0.010	0.010	mg/L		02/04/21 12:29	1	MG7H	
Lead	ND		0.0010	0.00069	mg/L		02/04/21 12:29	1	MG7H	

Client Sample ID: LADIES BR-1 Lab Sample ID: 630-12809-3

Matrix: Drinking Water Date Collected: 01/22/21 06:39

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS) Analyte Result Qualifier RL **MDL** Unit Analyzed Dil Fac Analyst Copper 0.050 0.010 0.010 mg/L 02/04/21 12:35 1 MG7H 0.0010 0.00069 mg/L 02/04/21 12:35 1 MG7H Lead 0.00075 J

Client Sample ID: LADIES BR-2 Lab Sample ID: 630-12809-4

Date Collected: 01/22/21 06:40 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS) Analyte Result Qualifier RL **MDL** Unit D Analyzed Dil Fac Analyst 0.010 0.010 mg/L 02/04/21 12:34 1 MG7H Copper 0.034 Lead ND 0.0010 0.00069 mg/L 02/04/21 12:34 1 MG7H

Lab Sample ID: 630-12809-5 Client Sample ID: ADM, BR

Date Collected: 01/22/21 06:41 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS) Analyte	•	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.056		0.010	0.010	mg/L		02/04/21 15:01	1	MG7H
Lead	ND		0.0010	0.00069	mg/L		02/04/21 15:01	1	MG7H

Client Sample ID: CHILDS BR-1 Lab Sample ID: 630-12809-6 Date Collected: 01/22/21 06:42 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS) Analyte Result Qualifier RL **MDL** Unit Analyzed Dil Fac Analyst Copper 0.010 0.010 mg/L 02/04/21 14:56 1 MG7H 0.074 Lead ND 0.0010 0.00069 mg/L 02/04/21 14:56 1 MG7H

Client Sample Results

Client: North Hudson Community Action Corp.

Project/Site: Head Start - 5800 Kennedy Blvd, WNY

Client Sample ID: CHILDS BR-2

Date Collected: 01/22/21 06:43 Date Received: 01/25/21 14:47 Lab Sample ID: 630-12809-7

Matrix: Drinking Water

Method: 200.8 - I	Vietals ((ICP/MS)
-------------------	-----------	----------

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.050		0.010	0.010	mg/L		02/04/21 15:08	1	MG7H
Lead	0.0016		0.0010	0.00069	mg/L		02/04/21 15:08	1	MG7H

Client Sample ID: CHILDS BR G-1

Date Collected: 01/22/21 06:50 Date Received: 01/25/21 14:47 Lab Sample ID: 630-12809-8

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

motifical zooio motalo (ici mio)	,									
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Copper	0.036		0.010	0.010	mg/L		02/04/21 15:12	1	MG7H	
Lead	ND		0.0010	0.00069	mg/L		02/04/21 15:12	1	MG7H	

Client Sample ID: CHILDS BR G-2

Date Collected: 01/22/21 06:51 Date Received: 01/25/21 14:47 Lab Sample ID: 630-12809-9

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.032		0.010	0.010	mg/L		02/04/21 15:15	1	MG7H
Lead	ND		0.0010	0.00069	mg/L		02/04/21 15:15	1	MG7H

Client Sample ID: SLOP SINK

Date Collected: 01/22/21 06:52 Date Received: 01/25/21 14:47 Lab Sample ID: 630-12809-10

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

INICITION. 200.0 - INICIAIS (ICF/INIS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Copper	0.041		0.010	0.010	mg/L		02/04/21 15:13	1	MG7H	
Lead	ND		0.0010	0.00069	mg/L		02/04/21 15:13	1	MG7H	

Client Sample ID: BATHROOM M-1

Date Collected: 01/22/21 06:35 Date Received: 01/25/21 14:47 Lab Sample ID: 630-12809-11
Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result Qualit	fier RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.067	0.010	0.010	mg/L		02/04/21 15:25	1	MG7H
Lead	ND	0.0010	0.00069	mg/L		02/04/21 15:25	1	MG7H

Client Sample ID: BATHROOM M-2

Date Collected: 01/22/21 06:36 Date Received: 01/25/21 14:47 Lab Sample ID: 630-12809-12

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Copper	0.067		0.010	0.010	mg/L		02/04/21 15:34	1	MG7H	
Lead	ND		0.0010	0.00069	ma/L		02/04/21 15:34	1	MG7H	

Client Sample Results

Client: North Hudson Community Action Corp. Project/Site: Head Start - 5800 Kennedy Blvd, WNY

Lab Sample ID: 630-12809-13

Client Sample ID: BATHROOM L1 Date Collected: 01/22/21 06:37

Date Received: 01/25/21 14:47

Matrix: Drinking Water

Job ID: 630-12809-1

Method:	200.8 -	Metals ((ICP/MS)
A I 4			

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.071		0.010	0.010	mg/L		02/04/21 13:04	1	MG7H
Lead	ND		0.0010	0.00069	mg/L		02/04/21 13:04	1	MG7H

Client Sample ID: BATHROOM L2 Lab Sample ID: 630-12809-14

Matrix: Drinking Water Date Collected: 01/22/21 06:38

Date Received: 01/25/21 14:47

Method: 200 8 - Metals (ICP/MS)

Method: 200.0 - Metals (101 /MO)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Copper	0.053		0.010	0.010	mg/L		02/04/21 15:39	1	MG7H	
Lead	ND		0.0010	0.00069	mg/L		02/04/21 15:39	1	MG7H	

Client Sample ID: KITCHEN PAN SINK

Lab Sample ID: 630-12809-15 Date Collected: 01/22/21 06:39 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.031		0.010	0.010	mg/L		02/04/21 15:07	1	MG7H
Lead	ND		0.0010	0.00069	mg/L		02/04/21 15:07	1	MG7H

Client Sample ID: KITCHEN HAND SINK

Date Collected: 01/22/21 06:40

Date Received: 01/25/21 14:47

Lab Sample ID: 630-12809-16

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.079		0.010	0.010	mg/L		02/04/21 15:10	1	MG7H
Lead	0.0012		0.0010	0.00069	mg/L		02/04/21 15:10	1	MG7H

Client Sample ID: KITCHEN RINSE SINK

Lab Sample ID: 630-12809-17 Date Collected: 01/22/21 06:41 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS)										
Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst	
Copper	0.023		0.010	0.010	mg/L		02/04/21 15:16	1	MG7H	
Lead	ND		0.0010	0.00069	mg/L		02/04/21 15:16	1	MG7H	

Client Sample ID: KITCHEN DISH WASHER SINK

Lab Sample ID: 630-12809-18 Date Collected: 01/22/21 06:42 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS) Analyte	Result Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.034	0.010	0.010	mg/L		02/04/21 15:30	1	MG7H
Lead	0.00080 J	0.0010	0.00069	mg/L		02/04/21 15:30	1	MG7H

Client: North Hudson Community Action Corp. Project/Site: Head Start - 5800 Kennedy Blvd, WNY

Client Sample ID: CLASS 41

Date Collected: 01/22/21 06:35 Date Received: 01/25/21 14:47

Lab Sample ID: 630-12809-19

Matrix: Drinking Water

Method: 200.8 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.088		0.010	0.010	mg/L		02/04/21 15:40	1	MG7H
Lead	ND		0.0010	0.00069	mg/L		02/04/21 15:40	1	MG7H

Client Sample ID: CLASS 7T Lab Sample ID: 630-12809-20

Date Collected: 01/22/21 06:36 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS) Analyte Result Qualifier MDL Unit Dil Fac Analyst RL Analyzed Copper 0.065 0.010 0.010 mg/L 02/04/21 15:42 1 MG7H 0.0010 02/04/21 15:42 Lead ND 0.00069 mg/L 1 MG7H

Client Sample ID: CHILDS BR B-1 Lab Sample ID: 630-12809-21

Date Collected: 01/22/21 06:53 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP/MS) Analyte Result Qualifier RL MDL Unit D Analyzed Dil Fac Analyst Copper 0.043 0.010 0.010 mg/L 02/04/21 15:31 1 MG7H Lead ND 0.0010 0.00069 mg/L 02/04/21 15:31 1 MG7H

Client Sample ID: CHILDS BR B-2 Lab Sample ID: 630-12809-22

Date Collected: 01/22/21 06:54 **Matrix: Drinking Water**

Date Received: 01/25/21 14:47

Method: 200.8 - Metals (ICP)	MS)							
Analyte	Result Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	0.061	0.010	0.010	mg/L		02/04/21 15:05	1	MG7H
Lead	ND	0.0010	0.00069	mg/L		02/04/21 15:05	1	MG7H

Action Limit Summary

Client: North Hudson Community Action Corp. Project/Site: Head Start - 5800 Kennedy Blvd, WNY Job ID: 630-12809-1

Lab Sample ID: 630-12809-1

Compliance Check

Client Sample ID: CLASS 9T

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

				NJ 1 MCL			
Analyte	Result Qu	ualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.060		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: CLASS 11T Lab Sample ID: 630-12809-2

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.045	mg/L	1	0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: LADIES BR-1 Lab Sample ID: 630-12809-3

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

				NJ 1 MCL			
Analyte	Result	Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.050		mg/L	1	0.010	200.8	Total/NA
Lead	0.00075	J	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: LADIES BR-2 Lab Sample ID: 630-12809-4

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result (Qualifier Un	it Limit	RL	Method	Prep Type
Copper	0.034	mg	/L 1	0.010	200.8	Total/NA
Lead	ND	mg	/L 0.02	0.0010	200.8	Total/NA

Client Sample ID: ADM. BR Lab Sample ID: 630-12809-5

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.056	mg/L	1	0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Lab Sample ID: 630-12809-6 Client Sample ID: CHILDS BR-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

	NJ 1 MCL					
Analyte	Result Qualifi	er Unit	Limit	RL	Method	Prep Type
Copper	0.074	mg/L	1	0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Action Limit Summary

Client: North Hudson Community Action Corp. Project/Site: Head Start - 5800 Kennedy Blvd, WNY

Client Sample ID: CHILDS BR-2 Lab Sample ID: 630-12809-7

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Qual	ifier Unit	Limit	RL	Method	Prep Type
Copper	0.050	mg/L		0.010	200.8	Total/NA
Lead	0.0016	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: CHILDS BR G-1

Lab Sample ID: 630-12809-8

Job ID: 630-12809-1

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Quali	fier Unit	Limit	RL	Method	Prep Type
Copper	0.036	mg/L	1	0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: CHILDS BR G-2

Lab Sample ID: 630-12809-9

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

				NJ 1 MCL			
Analyte	Result	Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.032		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: SLOP SINK

Lab Sample ID: 630-12809-10

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

				NJ 1 MCL			
Analyte	Result	Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.041		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: BATHROOM M-1

Lab Sample ID: 630-12809-11

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

_			NJ 1 MCL			
Analyte	Result Qualifie	er Unit	Limit	RL	Method	Prep Type
Copper	0.067	mg/L	1	0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: BATHROOM M-2

Lab Sample ID: 630-12809-12

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.067	mg/L	1	0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Job ID: 630-12809-1

Action Limit Summary

Client: North Hudson Community Action Corp.
Project/Site: Head Start - 5800 Kennedy Blvd, WNY

Client Sample ID: BATHROOM L1 Lab Sample ID: 630-12809-13

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.071	mg/L	1	0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: BATHROOM L2 Lab Sample ID: 630-12809-14

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Qua	alifier Unit	Limit	RL	Method	Prep Type
Copper	0.053	mg/L	1	0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: KITCHEN PAN SINK

Lab Sample ID: 630-12809-15

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

				NJ 1 MCL			
Analyte	Result	Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.031		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: KITCHEN HAND SINK Lab Sample ID: 630-12809-16

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.079	mg/L	1	0.010	200.8	Total/NA
Lead	0.0012	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: KITCHEN RINSE SINK

Lab Sample ID: 630-12809-17

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

	NJ 1 MCL									
Analyte	Result Qualifier	Unit	Limit	RL	Method	Prep Type				
Copper	0.023	mg/L	1	0.010	200.8	Total/NA				
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA				

Client Sample ID: KITCHEN DISH WASHER SINK Lab Sample ID: 630-12809-18

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.034	mg/L	1	0.010	200.8	Total/NA
Lead	0.00080 J	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: CLASS 41

Lab Sample ID: 630-12809-19

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

	NJ 1 MCL									
Analyte	Result	Qualifier	Unit	Limit	RL	Method	Prep Type			
Copper	0.088		mg/L	1	0.010	200.8	Total/NA			
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA			

Client Sample ID: CLASS 7T Lab Sample ID: 630-12809-20

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

				NJ 1 MCL			
Analyte	Result	Qualifier	Unit	Limit	RL	Method	Prep Type
Copper	0.065		mg/L	1	0.010	200.8	Total/NA
Lead	ND		mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: CHILDS BR B-1 Lab Sample ID: 630-12809-21

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

				NJ 1 MCL			
Ana	ılyte	Result Qual	lifier Unit	Limit	RL	Method	Prep Type
Сор	per	0.043	mg/L	1	0.010	200.8	Total/NA
Lea	d	ND	mg/L	0.02	0.0010	200.8	Total/NA

Client Sample ID: CHILDS BR B-2 Lab Sample ID: 630-12809-22

Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

			NJ 1 MCL			
Analyte	Result Qua	lifier Unit	Limit	RL	Method	Prep Type
Copper	0.061	mg/L		0.010	200.8	Total/NA
Lead	ND	mg/L	0.02	0.0010	200.8	Total/NA

Accreditation/Certification and Definitions Summary

Client: North Hudson Community Action Corp.

Project/Site: Head Start - 5800 Kennedy Blvd, WNY

Job ID: 630-12809-1

Laboratory: Eurofins Lancaster Laboratories Env, LLC

The accreditations/certifications listed below are applicable to this report.

	Authority	Program	Identification Number	Expiration Date
New Jersey NELAP PA011 06-30-21	New Jersey	NELAP	PA011	06-30-21

Qualifiers

Metals

Qualifier Qualifier Description

J Result is less than the RL but greater than or equal to the MDL and the concentration is an approximate value.

Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.								
¤	Listed under the "D" column to designate that the result is reported on a dry weight basis								
%R	Percent Recovery								
1C	Result is from the primary column on a dual-column method.								
2C	Result is from the confirmation column on a dual-column method.								
CFL	Contains Free Liquid								
CFU	Colony Forming Unit								
CNF	Contains No Free Liquid								
DER	Duplicate Error Ratio (normalized absolute difference)								
Dil Fac	Dilution Factor								
DL	Detection Limit (DoD/DOE)								
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample								
DLC	Decision Level Concentration (Radiochemistry)								
EDL	Estimated Detection Limit (Dioxin)								
LOD	Limit of Detection (DoD/DOE)								
LOQ	Limit of Quantitation (DoD/DOE)								
MCL	EPA recommended "Maximum Contaminant Level"								
MDA	Minimum Detectable Activity (Radiochemistry)								
MDC	Minimum Detectable Concentration (Radiochemistry)								

MDC Minimum Detectable Cond MDL Method Detection Limit ML Minimum Level (Dioxin) MPN Most Probable Number MQL Method Quantitation Limit

NC Not Calculated

ND Not Detected at the reporting limit (or MDL or EDL if shown)

NEG Negative / Absent POS Positive / Present

PQL Practical Quantitation Limit

PRES Presumptive QC Quality Control

RER Relative Error Ratio (Radiochemistry)

RL Reporting Limit or Requested Limit (Radiochemistry)

RPD Relative Percent Difference, a measure of the relative difference between two points

TEF Toxicity Equivalent Factor (Dioxin)
TEQ Toxicity Equivalent Quotient (Dioxin)

TNTC Too Numerous To Count

Eurofins QC, LLC – Horsham, PA 5/5/2021 (Rev. 1)

Method Summary

Client: North Hudson Community Action Corp. Project/Site: Head Start - 5800 Kennedy Blvd, WNY Job ID: 630-12809-1

Laboratory	

Method	Method Description	Protocol	Laboratory
200.8	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

Protocol References:

EPA = US Environmental Protection Agency

Laboratory References:

ELLE = Eurofins Lancaster Laboratories Env, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300

2

_

5

7

2

5

6

Я

3

702 Electronic Drive

Horsham, PA 19044-0962

Chain of Custody Record



🔅 eurofins

Environment Testing America

Client Information (Sub Contract Lab)	Sampler:					PM: gherty, Erin					Carrier Tracking No(s)				COC No: 630-3664.1			
Client Contact: Shipping/Receiving	Phone:			E-Ma Erin		State of Origin: lougherty@eurofinset.com New Jersey									Page: Page 1 of 3			
Company:				1	Accred	ditation	s Rec	uired (Se		e):							Job #:	
Eurofins Lancaster Laboratories Env LLC	Due Date Request	ed:			NEL	4P - N	vew.	Jersey									630-12809-1 Preservation Cod	les:
2425 New Holland Pike, ,	2/5/2021								Ana	lysis	Req	ueste	d				A - HCL	M - Hexane
city: Lancaster	TAT Requested (d	ays):															B - NaOH C - Zn Acetate	N - None O - AsNaO2
state, Zip. PA, 17601														D - Nitric Acid P - Na2O4S E - NaHSO4 Q - Na2SO3				
Phone: 217-656-2300(Tel)	PO #:				b only											F - MeOH G - Amchlor	R - Na2S2O3 S - H2SO4	
nail: WO#:				Sample (Yes or No)	Cu & Pb										ah	H - Ascorbic Acid I - Ice J - DI Water	T - TSP Dodecahydrat U - Acetone V - MCAA	
Project Name:	Project #:				(Yes		1		i							iner	K - EDTA L - EDA	W - pH 4-5 Z - other (specify)
lorth Hudson-Head Start PB/CU ite:	63003775 SSOW#:	63003775				9										conta	Other:	(
	00071111					Ę										o Jo		
		Sample	Sample Type (C=comp,	Matrix (W=water, S=solid, O=waste/oil,	old Filtered	S.										tal Number		
Sample Identification - Client ID (Lab ID)	Sample Date	Time		BT=Tissue, A=Air)	Perf	200.8										Total	Special In	structions/Note:
		06:37		tion Code:	Y											X		
CLASS 9T (630-12809-1)	1/22/21	Eastern		rinking Wat		X		$\sqcup \bot$						\sqcup		1		
CLASS 11T (630-12809-2)	1/22/21	06:38 Eastern		rinking Wat		X										1		
ADIES BR-1 (630-12809-3)	1/22/21	06:39 Eastern		rinking Wat		×						\perp				1		
ADIES BR-2 (630-12809-4)	1/22/21	06:40 Eastern		rinking Wat	1	×										1		
DM. BR (630-12809-5)	1/22/21	06:41 Eastern		rinking Wat		×										1		
:HILDS BR-1 (630-12809-6)	1/22/21	06:42 Eastern		rinking Wat		×										1		
CHILDS BR-2 (630-12809-7)	1/22/21	06:43 Eastern		rinking Wat	1	×										1		
HILDS BR G-1 (630-12809-8)	1/22/21	06:50 Eastern		rinking Wat	1	×								\Box		1		
CHILDS BR G-2 (630-12809-9)	1/22/21	06:51 Eastern		rinking Wat	1	×										1		
ote: Since laboratory accreditations are subject to change, Eurofins QC of currently maintain accreditation in the State of Origin listed above for rought to Eurofins QC, LLC Horsham, PA attention immediately. If all	analysis/tests/matrix being a	s the ownershi	amples must b	e shipped bac	k to the Custoo	Eurofi dy atte	ins QC sting t	c, LLC – I o said co	Horsha mplica	am, PA I nce to I	laborat Eurofin:	ory or oth s QC, LL	ner instr C – Hor	uctions sham, F	will be p PA.	rovide	ed. Any changes to a	ccreditation status should
Possible Hazard Identification					s	$\overline{}$		•		e may				•	s are r		ned longer than '	· · · · · · · · · · · · · · · · · · ·
Inconfirmed Deliverable Requested: I, II, III, IV, Other (specify)	Primary Deliver	able Rank:	1		S			n To Cl		Reaui		<i>isposai</i> nts:	By La	a		Arch	hive For	Months
	·	Date:			Time					· - m - ·			ethod of	Shinm	ent:			
empty Kit Relinquished by:				Company	Lime		eived	bv.					ou lou oi	Date/				Company
1/Con	112	5/211	440	EQU													/	
Relinquished by:	Date/Time:	/		Company	/	Red	eived	by:			1			Date/	I ime:		1	Company
Relinquished by:	Date/Time:	/		Company		Rec	eived	by_	0	2				Date	Time:	71	2140	Company
Custody Seals Intact: Custody Seal No.:		L				Cod	oler Te	mperatu	re(s) °C	C and C	ther R	emarks:	•		100		-1100	
Yes A No													ت	L 2	<i>icl</i>	50	S/EKK	Ve 5/5/020021 (

EIIF- 7 Q

Eurofins QC, LLC - Horsham, PA

702 Electronic Drive

Horsham, PA 19044-0962

Chain of Custody Record

eurofins	Environment	Test
	1	

ing America

Veb/15/12/02/1 (Rev. 1

Phone: 215-355-3900 Fax: 888-785-8567 Sampler: Lab PM Carrier Tracking No(s): COC No: Client Information (Sub Contract Lab) Dougherty, Erin 630-3664.2 Client Contact: hone: E-Mail State of Origin: Page: Shipping/Receiving Erin.Dougherty@eurofinset.com Page 2 of 3 New Jersey Company: Accreditations Required (See note): Job #: Eurofins Lancaster Laboratories Env LLC NELAP - New Jersey 630-12809-1 Address: Due Date Requested: Preservation Codes: 2425 New Holland Pike, 2/5/2021 **Analysis Requested** A - HCL M - Hexane City: TAT Requested (days): B - NaOH N - None Lancaster O - AsNaO2 C - Zn Acetate State, Zip. D - Nitric Acid P - Na2O4S E - NaHSO4 Q - Na2SO3 PA, 17601 F - MeOH R - Na2S2O3 Phone: PO #: G - Amchior S - H2SO4 717-656-2300(Tel) 200.8_SDWA/MTL_ND_Prep Cu & Pb H - Ascorbic Acid T - TSP Dodecahydrate Email: WO# I - Ice U - Acetone J - DI Water V - MCAA containers K - EDTA W - pH 4-5 Project Name Project # Z - other (specify) L - EDA North Hudson-Head Start PB/CU 63003775 SSOW#: Other: Total Number of Matrix Sample (w=water, Type Sample (C=comp, O=waste/oil, Sample Identification - Client ID (Lab ID) Sample Date Time G=grab) | BT=Tissue, A=Air) Special Instructions/Note: Preservation Code: 06:52 SLOP SINK (630-12809-10) 1/22/21 rinking Wat Х Eastern 06:35 BATHROOM M-1 (630-12809-11) 1/22/21 rinking Wate Х Eastern 06:36 BATHROOM M-2 (630-12809-12) 1/22/21 rinking Wate Х Eastern 06:37 BATHROOM L1 (630-12809-13) Х 1/22/21 rinking Wate Eastern 06:38 BATHROOM L2 (630-12809-14) 1/22/21 rinking Wat Х 1 Eastern 06:39 KITCHEN PAN SINK (630-12809-15) Х 1/22/21 rinking Wat Eastern 06:40 KITCHEN HAND SINK (630-12809-16) Х 1/22/21 rinking Wat Eastern 06:41 KITCHEN RINSE SINK (630-12809-17) 1/22/21 rinking Wat Х Eastern 06:42 KITCHEN DISH WASHER SINK (630-12809-18) 1/22/21 rinking Wat Eastern Note: Since laboratory accreditations are subject to change, Eurofins QC, LLC - Horsham, PA places the ownership of method, analyte & accreditation compliance upon out subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins QC, LLC - Horsham, PA laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins QC, LLC - Horsham, PA attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said complicance to Eurofins QC, LLC - Horsham, PA Possible Hazard Identification Sample Disposal (A fee may be assessed if samples are retained longer than 1 month) Return To Client Unconfirmed Disposal By Lab $^{
ightharpoonup}$ Archive For Months Deliverable Requested: I, II, III, IV, Other (specify) Primary Deliverable Rank: 1 Special Instructions/QC Requirements Empty Kit Relinquished by: Date: Method of Shipment Time: Relinquished by Received by: Date/Time Company Relinguished by Date/Time Received by Date/Time Date/Time Relinquished by Company Received by Custody Seals Intact: Custody Seal No. Cooler Temperature(s) °C and Other Remarks: Yes A No

Page 19 of 20

Eurofins QC, LLC - Horsham, PA

702 Electronic Drive

Horsham, PA 19044-0962

Chain of Custody Record

	eurofins	
--	----------	--

Eilern Q

Environment Testing America

Client Information (Sub Contract Lab)	Sampler:							M: gherty, Erin						(s):		COC No: 630-3664.3	
lient Contact:	Phone:	Phone: E-Ma						il:								Page: Page 3 of 3	
hipping/Receiving		.Dougherty@eurofinset.com Accreditations Required (See note)							New Jersey				Job#:				
Company: Eurofins Lancaster Laboratories Env LLC								NELAP - New Jersey									
ddress: 425 New Holland Pike, ,		Due Date Requested: 2/5/2021							Analysis Reque							Preservation Co	
ity		TAT Requested (days):						<u> </u>	T	1	1	1		\top	800	A - HCL B - NaOH	M - Hexane N - None
ancaster																C - Zn Acetate D - Nitric Acid	O - AsNaO2 P - Na2O4S
tate, Zip: A, 17601						only										E - NaHSO4	Q - Na2SO3
hone:	PO #:	PO#:														F - MeOH G - Amchlor	R - Na2S2O3 S - H2SO4
17-656-2300(Tel) mail:	WO #:				2	& Pb										H - Ascorbic Acid	T - TSP Dodecahydrat U - Acetone
naii.	1.0 #				Yes or	3									2	J - DI Water K - EDTA	V - MCAA W - pH 4-5
roject Name	Project #: 63003775														laine	L - EDA	Z - other (specify)
orth Hudson-Head Start PB/CU	SSOW#:														con	Other:	
					ered Sample	} €									rof		
			Sample	Matrix	De la	SDWA/MTL_ND_Prep									agu		
			Type	(W=water, S≃solid,		S									N		
ample Identification - Client ID (Lab ID)	Sample Date	Sample Time	(C=comp, G=grab)	O=waste/oil, BT=Tissue, A=Air	Field Filt	200.8									Total	Special	nstructions/Note:
ample racination of the control (Lab is)		><		ation Code:	X										X		
LASS 41 (630-12809-19)	1/22/21	06:35 Eastern	1	rinking Wa	te	×									1		
ASS 7T (630-12809-20)	1/22/21	06:36 Eastern		rinking Wa	te	×									1		
HILDS BR B-1 (630-12809-21)	1/22/21	06:53 Eastern		rinking Wa	te	X									1		
HILDS BR B-2 (630-12809-22)	1/22/21	06:54 Eastern		rinking Wa	te	×				\perp		\perp		$\perp \perp$	1		
					Ш	_	ļ		_			_		$\perp \perp$			
								Ш									
					T		T										
					++	+	\vdash			+		+		+			
			l	L								L					
ote: Since laboratory accreditations are subject to change, Eurofins Q0 ot currently maintain accreditation in the State of Origin listed above for	r analysis/tests/matrix being a	analyzed, the s	amples must	be shipped ba	ck to the	e Eurofi	ns QC	LLC-F	Horsha	m. PA la	aborator	y or other	r instructi	ons will be	s forward e provide	ded under chain-of-o ed. Any changes to	ustody. If the laboratory d accreditation status should
bught to Eurofins QC, LLC – Horsham, PA attention immediately. If all	requested accreditations ar	e current to da	ite, return the	signed Chain	of Custo	dy atte	sting to	said cor	mplicar	nce to E	urofins	QC, LLC	– Horsha	m, PA.			
ossible Hazard Identification					s	ampl	e Dis	posal (A fe	e may	be as	sessed	if sam	ples are	\neg	ned longer thar	1 month)
Inconfirmed			Return To Client											hive For	Months		
eliverable Requested: I, II, III, IV, Other (specify)	Primary Deliver	able Rank:	1		S	pecia	l Insti	uctions	/QC I	Requir	ement	s:					
mpty Kit Relinquished by:		Date:			Time	9:						Meth	od of Sh	ipment:			
elinquished by:	Date/Tinfe:	Date/Tinfe: 25/21 1440 Company				Received by:						Date/Time:				/	Company
elinquished by:	Date/Time:	Date/Tilne: Company					Received by: Date/Time: Comp									Company	
elinquished by:	Date/Time: Compar						eived	by:	1	4_			D	ate/Time	17,	-2140	Company
Custody Seals Intact: Custody Seal No.:		1				Cor	lor To	mperatur	0/2) %	and Of	har Da	nadia:	1 .	oc !	U	Jelli	ELLE

3

6