



# ANALYTICAL REPORT

## PREPARED FOR

Attn: Jay Johnson  
North Hudson Community Action Corp.  
5800 Kennedy Boulevard  
West New York, New Jersey 07093

Generated 6/10/2024 11:13:06 AM

## JOB DESCRIPTION

North Hudson - Head Start - PB/CU - 380 Kearny Ave

## JOB NUMBER

630-86796-1

# Eurofins Environment Testing Philadelphia, LLC

## Job Notes

This report may not be reproduced except in full, and with written approval from the laboratory. The results relate only to the samples tested. For questions please contact the Project Manager at the e-mail address or telephone number listed on this page.

The test results in this report relate only to the samples as received by the laboratory and will meet all requirements of the methodology, with any exceptions noted. This report shall not be reproduced except in full, without the express written approval of the laboratory. All questions should be directed to the Eurofins Environment Testing Philadelphia, LLC Project Manager.

## Authorization



Generated  
6/10/2024 11:13:06 AM

Authorized for release by  
Erin Dougherty, Project Administrator  
[Erin.Dougherty@et.eurofinsus.com](mailto:Erin.Dougherty@et.eurofinsus.com)  
(215)355-3900

## Compliance Statement

Analytical test results meet all requirements of the associated regulatory program (e.g., NELAC (TNI), DoD, and ISO 17025) unless otherwise noted under the individual analysis. Data qualifiers are applied to note exceptions. Noncompliant quality control (QC) is further explained in narrative comments. QC data that exceed the upper limits and are associated with non-detect samples are qualified but no further narration is needed since the bias is high and does not change a non-detect result. Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

### Coliform MCLs

· Based on the EPA primary drinking water standard MCL for total coliforms, a water supply is considered bacteriologically "SAFE" if no coliform bacteria are detected. To be considered "SAFE" your report should indicate "<1 cfu/100mL" or "NEG" for the coliform test. If you report indicates a positive result "POS" or a value greater than or equal to one, then your supply is "UNSAFE FOR DRINKING" contact your local health department.

### Warranties, Terms, and Conditions

· Analyses for Field Parameters are performed by Eurofins Philadelphia field staff. Locations and certifications are identified on the Chain of Custody as follows:

ERF = field staff performs tests under NJ State certification # 02015.

VL = field staff performs tests under NJ State certification # 06005.

WG = field staff performs tests under NJ State certification # PA001, PA State certification # 48-01334.

H = field staff performs tests under NJ NELAP certification # PA093, PA NELAP certification # 46-05499.

· Test results meet all TNI or other applicable regulatory agency requirements, including holding times and preservation, unless otherwise indicated.

· The report shall not be reproduced, except in full, without the written consent of the laboratory

· All samples are collected as "grab" samples unless otherwise identified.

· Reported results related only to the samples as tested. Eurofins Philadelphia is not responsible for sample integrity unless sampling has been performed by a member of our staff.

· Eurofins Philadelphia is not responsible for sampling and/or testing omissions. Note that regulatory authorities may assess substantial fines for testing omissions. Please track your sample collection schedules and results on a regular basis (e.g. weekly, monthly, or quarterly) to ensure compliance.

· Eurofins' online data portal "TotalAccess" will provide you with real-time access to collection dates and testing results. Please contact Client Services for further information.

· The following personnel or their deputies have approved the results of the tests performed by Eurofins Philadelphia : Nicki Smith (Environmental Chemistry) and Jacqueline Gartner (Water Microbiology).



---

# Case Narrative

Client: North Hudson Community Action Corp.  
Project: North Hudson - Head Start - PB/CU - 380 Kearny Ave

Job ID: 630-86796-1

**Job ID: 630-86796-1**

**Eurofins Environment Testing Philadelphia,**

## **Job Narrative 630-86796-1**

Analytical test results meet all requirements of the associated regulatory program listed on the Accreditation/Certification Summary Page unless otherwise noted under the individual analysis. Data qualifiers are applied to indicate exceptions. Noncompliant quality control (QC) is further explained in narrative comments.

- Matrix QC may not be reported if insufficient sample or site-specific QC samples were not submitted. In these situations, to demonstrate precision and accuracy at a batch level, a LCS/LCSD may be performed, unless otherwise specified in the method.
- Surrogate and/or isotope dilution analyte recoveries (if applicable) which are outside of the QC window are confirmed unless attributed to a dilution or otherwise noted in the narrative.

Regulated compliance samples (e.g. SDWA, NPDES) must comply with the associated agency requirements/permits.

### **Receipt**

The samples were received on 5/29/2024 4:00 PM. Unless otherwise noted below, the samples arrived in good condition, and, where required, properly preserved and on ice. The temperature of the cooler at receipt time was 4.5°C.

### **Metals**


No additional analytical or quality issues were noted, other than those described above or in the Definitions/ Glossary page.

# Sample Summary

Client: North Hudson Community Action Corp.  
Project/Site: North Hudson - Head Start - PB/CU - 380 Kearny Ave

Job ID: 630-86796-1

Lab Sample ID	Client Sample ID	Matrix	Collected	Received
630-86796-1	380 KEARNY AVE GIRLS BR #1	Drinking Water	05/22/24 07:30	05/29/24 16:00
630-86796-2	380 KEARNY AVE GIRLS BR #2	Drinking Water	05/22/24 07:31	05/29/24 16:00
630-86796-3	380 KEARNY AVE BOYS BR #1	Drinking Water	05/22/24 07:34	05/29/24 16:00
630-86796-4	380 KEARNY AVE BOYS BR #2	Drinking Water	05/22/24 07:33	05/29/24 16:00
630-86796-5	380 KEARNY AVE TODDLERS CLASSROOM SINK	Drinking Water	05/22/24 07:40	05/29/24 16:00
630-86796-6	380 KEARNY AVE TODDLERS BR	Drinking Water	05/22/24 07:42	05/29/24 16:00
630-86796-7	380 KEARNY AVE KITCHEN	Drinking Water	05/22/24 07:45	05/29/24 16:00



# Client Sample Results

Client: North Hudson Community Action Corp.  
Project/Site: North Hudson - Head Start - PB/CU - 380 Kearny Ave

Job ID: 630-86796-1

## Client Sample ID: 380 KEARNY AVE GIRLS BR #1

Lab Sample ID: 630-86796-1

Date Collected: 05/22/24 07:30

Matrix: Drinking Water

Date Received: 05/29/24 16:00

### Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	55		10	2.3	ug/L		06/04/24 09:15	1	S4PD
Lead	3.6		1.0	0.69	ug/L		06/04/24 09:15	1	S4PD

## Client Sample ID: 380 KEARNY AVE GIRLS BR #2

Lab Sample ID: 630-86796-2

Date Collected: 05/22/24 07:31

Matrix: Drinking Water

Date Received: 05/29/24 16:00

### Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	57		10	2.3	ug/L		06/04/24 10:03	1	S4PD
Lead	1.3		1.0	0.69	ug/L		06/04/24 10:03	1	S4PD

## Client Sample ID: 380 KEARNY AVE BOYS BR #1

Lab Sample ID: 630-86796-3

Date Collected: 05/22/24 07:34

Matrix: Drinking Water

Date Received: 05/29/24 16:00

### Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	49		10	2.3	ug/L		06/04/24 09:10	1	S4PD
Lead	5.0		1.0	0.69	ug/L		06/04/24 09:10	1	S4PD

## Client Sample ID: 380 KEARNY AVE BOYS BR #2

Lab Sample ID: 630-86796-4

Date Collected: 05/22/24 07:33

Matrix: Drinking Water

Date Received: 05/29/24 16:00

### Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	53		10	2.3	ug/L		06/05/24 14:52	1	S4PD
Lead	ND		1.0	0.69	ug/L		06/05/24 14:52	1	S4PD

## Client Sample ID: 380 KEARNY AVE TODDLERS CLASSROOM SINK

Lab Sample ID: 630-86796-5

Date Collected: 05/22/24 07:40

Matrix: Drinking Water

Date Received: 05/29/24 16:00

### Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	68		10	2.3	ug/L		06/04/24 09:17	1	S4PD
Lead	2.1		1.0	0.69	ug/L		06/04/24 09:17	1	S4PD

## Client Sample ID: 380 KEARNY AVE TODDLERS BR

Lab Sample ID: 630-86796-6

Date Collected: 05/22/24 07:42

Matrix: Drinking Water

Date Received: 05/29/24 16:00

### Method: 200.8 Rev 5.4 - Metals (ICP/MS)

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	72		10	2.3	ug/L		06/04/24 09:21	1	S4PD
Lead	3.7		1.0	0.69	ug/L		06/04/24 09:21	1	S4PD

# Client Sample Results

Client: North Hudson Community Action Corp.  
Project/Site: North Hudson - Head Start - PB/CU - 380 Kearny Ave

Job ID: 630-86796-1

**Client Sample ID: 380 KEARNY AVE KITCHEN**

**Lab Sample ID: 630-86796-7**

Date Collected: 05/22/24 07:45

Matrix: Drinking Water

Date Received: 05/29/24 16:00

**Method: 200.8 Rev 5.4 - Metals (ICP/MS)**

Analyte	Result	Qualifier	RL	MDL	Unit	D	Analyzed	Dil Fac	Analyst
Copper	36		10	2.3	ug/L		06/05/24 15:04	1	S4PD
Lead	ND		1.0	0.69	ug/L		06/05/24 15:04	1	S4PD

# Action Limit Summary

Client: North Hudson Community Action Corp.  
Project/Site: North Hudson - Head Start - PB/CU - 380 Kearny Ave

Job ID: 630-86796-1

## Client Sample ID: 380 KEARNY AVE GIRLS BR #1

Lab Sample ID: 630-86796-1

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	55		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	3.6		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

## Client Sample ID: 380 KEARNY AVE GIRLS BR #2

Lab Sample ID: 630-86796-2

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	57		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	1.3		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

## Client Sample ID: 380 KEARNY AVE BOYS BR #1

Lab Sample ID: 630-86796-3

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	49		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	5.0		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

## Client Sample ID: 380 KEARNY AVE BOYS BR #2

Lab Sample ID: 630-86796-4

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	53		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

## Client Sample ID: 380 KEARNY AVE TODDLERS CLASSROOM SINK

Lab Sample ID: 630-86796-5

### Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	68		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	2.1		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA



# Action Limit Summary

Client: North Hudson Community Action Corp.  
Project/Site: North Hudson - Head Start - PB/CU - 380 Kearny Ave

Job ID: 630-86796-1

**Client Sample ID: 380 KEARNY AVE TODDLERS BR**

**Lab Sample ID: 630-86796-6**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	72		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	3.7		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

**Client Sample ID: 380 KEARNY AVE KITCHEN**

**Lab Sample ID: 630-86796-7**

## Compliance Check

The results obtained from the analytical testing of this data set were checked against compliance limits received from the client. Any results at or above the compliance limits have been highlighted for your convenience.

Analyte	Result	Qualifier	Unit	NJ 1 MCL		RL	Method	Prep Type
				Limit				
Copper	36		ug/L	1349		10	200.8 Rev 5.4	Total/NA
Lead	ND		ug/L	15.4		1.0	200.8 Rev 5.4	Total/NA

# Accreditation/Certification and Definitions Summary

Client: North Hudson Community Action Corp.  
 Project/Site: North Hudson - Head Start - PB/CU - 380 Kearny Ave

Job ID: 630-86796-1

## Laboratory: Eurofins Lancaster Laboratories Environment Testing, LLC

The accreditations/certifications listed below are applicable to this report.

Authority	Program	Identification Number	Expiration Date
New Jersey	NELAP	PA011	06-30-24

## Glossary

Abbreviation	These commonly used abbreviations may or may not be present in this report.
α	Listed under the "D" column to designate that the result is reported on a dry weight basis
%R	Percent Recovery
1C	Result is from the primary column on a dual-column method.
2C	Result is from the confirmation column on a dual-column method.
CFL	Contains Free Liquid
CFU	Colony Forming Unit
CNF	Contains No Free Liquid
DER	Duplicate Error Ratio (normalized absolute difference)
Dil Fac	Dilution Factor
DL	Detection Limit (DoD/DOE)
DL, RA, RE, IN	Indicates a Dilution, Re-analysis, Re-extraction, or additional Initial metals/anion analysis of the sample
DLC	Decision Level Concentration (Radiochemistry)
EDL	Estimated Detection Limit (Dioxin)
LOD	Limit of Detection (DoD/DOE)
LOQ	Limit of Quantitation (DoD/DOE)
MCL	EPA recommended "Maximum Contaminant Level"
MDA	Minimum Detectable Activity (Radiochemistry)
MDC	Minimum Detectable Concentration (Radiochemistry)
MDL	Method Detection Limit
ML	Minimum Level (Dioxin)
MPN	Most Probable Number
MQL	Method Quantitation Limit
MRL	Method Reporting Limit
NC	Not Calculated
ND	Not Detected at the reporting limit (or MDL or EDL if shown)
NEG	Negative / Absent
POS	Positive / Present
PQL	Practical Quantitation Limit
PRES	Presumptive
QC	Quality Control
RER	Relative Error Ratio (Radiochemistry)
RL	Reporting Limit or Requested Limit (Radiochemistry)
RPD	Relative Percent Difference, a measure of the relative difference between two points
SDL	Sample Detection Limit
SDL	Sample Detection Limit
SDL	Sample Detection Limit
TEF	Toxicity Equivalent Factor (Dioxin)
TEQ	Toxicity Equivalent Quotient (Dioxin)
TNTC	Too Numerous To Count

# Method Summary

Client: North Hudson Community Action Corp.  
Project/Site: North Hudson - Head Start - PB/CU - 380 Kearny Ave

Job ID: 630-86796-1

---

---


Method	Method Description	Protocol	Laboratory
200.8 Rev 5.4	Metals (ICP/MS)	EPA	ELLE
Non-Digest Prep	Preparation, Non-Digested Aqueous Metals	EPA	ELLE

**Protocol References:**

EPA = US Environmental Protection Agency

**Laboratory References:**

ELLE = Eurofins Lancaster Laboratories Environment Testing, LLC, 2425 New Holland Pike, Lancaster, PA 17601, TEL (717)656-2300






Environment Testing  
America

213 Witmer Road Phone: 215-355-3900  
Horsham, PA 19044

Client/Acct. No. \_\_\_\_\_  
Address 5800 Kennedy Blvd  
West New York NJ 07093  
City/State/Zip \_\_\_\_\_  
Phone/Fax 201-617-0901  
Client Contact: Jay Johnson



630-86796 Chain of Custody

Bill to/Report to (

Sampling Site Address (if different) Include State

380 Kearny Ave  
Kearny NJ

P.O. No. \_\_\_\_\_ PWSID #: \_\_\_\_\_  
Quote # \_\_\_\_\_  
e-mail: \_\_\_\_\_

Loc: 630  
**86796**

Lab LIMS N

LAB USE O

# \_\_\_ Ascorbic/HCL Vials # \_\_\_ HCl Vials  
# \_\_\_ Na<sub>2</sub>S<sub>2</sub>O<sub>3</sub> \_\_\_\_\_  
# \_\_\_ Na OH/Zn acetate pH \_\_\_\_\_  
# \_\_\_ HNO<sub>3</sub> pH \_\_\_\_\_  
# \_\_\_ H<sub>2</sub>SO<sub>4</sub> pH \_\_\_\_\_  
# \_\_\_ NaOH pH \_\_\_\_\_  
# \_\_\_ Unpreserved  
# \_\_\_ HCl # \_\_\_ NH<sub>4</sub>Cl # \_\_\_ MeOH  
# \_\_\_ DI Water

MATRIX CODES

DW: DRINKING WATER  
GW: GROUND WATER  
WW: WASTEWATER  
SO: SOIL  
SL: SLUDGE  
OIL: OIL  
SOL: NON SOIL SOLID  
MI: MISCELLANEOUS  
X: OTHER

LAB USE ONLY	PROJECT	Collection		G R A B	C O M P	Matrix Code	Number of Containers														
	FIELD ID	Date	Military Time				Total	H	H	V	H	N	Z	U	B						
								2	C	I	N	a	n	N	A						
	Girls BR # 1	5/22/24	0730																		
	Girls BR # 2	5/22/24	0731																		
	Boys BR # 1	5/22/24	0734																		
	Boys BR # 2	5/22/24	0733																		
	Toddlers Classroom Sink	5/22/24	0740																		
	Toddlers BR	5/22/24	0742																		
	Kitchen	5/22/24	0745																		

ANALYSIS REQUESTED

Field pH, Temp (°C), DO, Cl<sub>2</sub>, Cond. etc.

Lead and copper

SAMPLED BY: (Name/Company) \_\_\_\_\_ TAT:  STANDARD (10 DAY) or DUE DATE \_\_\_\_/\_\_\_\_/\_\_\_\_ Report Format:  Standard  NJ-RDD  SRP-RDD  Standard + QC  Forms  EDD

Field Parameters Analyzed By: \_\_\_\_\_ Initials \_\_\_\_\_ Date/Time: \_\_\_\_\_

Please call for pricing and availability for rush (<10 day) turnaround and for all but standard reporting format.

SAMPLE CUSTODY EXCHANGES MUST BE DOCUMENTED BELOW. USE FULL LEGAL SIGNATURE, DATE AND MILITARY TIME (24 HOUR CLOCK, I.E. 8AM IS 0800, 4 PM IS 1600)

RELINQUISHED BY/SAMPLER	DATE	TIME	RECEIVED BY	DATE	TIME	DELIVERY: <input type="checkbox"/> EQC COURIER <input type="checkbox"/> CLIENT <input type="checkbox"/> UPS <input type="checkbox"/> FEDEX <input type="checkbox"/> OTHER	Custody Seal Number
1. <u>Jay Johnson</u>	5/29/24	1:04	1. <u>Andres Betancur</u>	5/29/24	1304		
2. <u>Andres Betancur</u>	5/29/24	1600	2. <u>CLR 131</u>	5/29/24	1600	Rec'd Temp.: <u>4.5°C</u> <del>15°C</del> Initials: <u>AB</u> Ice <input checked="" type="checkbox"/> Location: <u>ERC</u>	
3. _____	DATE	TIME	RECEIVED BY	DATE	TIME	COMMENTS:	
4. _____	DATE	TIME	RECEIVED BY	DATE	TIME		
5. _____	DATE	TIME	RECEIVED BY	DATE	TIME		

**Eurofins Environment Testing Philadelphia,**

795 Horsham Road  
 Horsham, PA 19044-0962  
 Phone: 215-355-3900

**Chain of Custody Record**



<b>Client Information (Sub Contract Lab)</b>		Sampler:		Lab PM: Dougherty, Erin		Carrier Tracking No(s):		COC No: 630-14337 1																					
Client Contact: Shipping/Receiving		Phone:		E-Mail: Erin.Dougherty@et.eurofinsus.com		State of Origin New Jersey		Page: Page 1 of 1																					
Company: Eurofins Lancaster Laboratories Environm				Accreditations Required (See note): NELAP - New Jersey				Job #: 630-86796-1																					
Address: 2425 New Holland Pike,		Due Date Requested: 6/11/2024		<b>Analysis Requested</b>						<b>Preservation Codes:</b>																			
City: Lancaster		TAT Requested (days):																											
State, Zip: PA, 17601		PO #:																											
Phone: 717-656-2300(Tel)		WO #:																											
Email:		Project #: 63003775		Project Name: North Hudson - Head Start - CU/PB - 380 Kearny Ave		SSOW#:		Site:																					
<b>Sample Identification - Client ID (Lab ID)</b>		<b>Sample Date</b>		<b>Sample Time</b>		<b>Sample Type (C=comp, G=grab)</b>		<b>Matrix (W=water, S=solid, O=waste/soil, BT=Tissue, A=Air)</b>		<b>Field Filtered Sample (Yes or No)</b>		<b>Perform MS/MSD (Yes or No)</b>		<b>200 B/MTL_ND_Prep (MOD) Lead/Copper</b>		<b>Total Number of Containers</b>		<b>Special Instructions/Note:</b>											
380 KEARNY AVE GIRLS BR #1 (630-86796-1)		5/22/24		07:30 Eastern		Drinking Water				X						1													
380 KEARNY AVE GIRLS BR #2 (630-86796-2)		5/22/24		07:31 Eastern		Drinking Water				X						1													
380 KEARNY AVE BOYS BR #1 (630-86796-3)		5/22/24		07:34 Eastern		Drinking Water				X						1													
380 KEARNY AVE BOYS BR #2 (630-86796-4)		5/22/24		07:33 Eastern		Drinking Water				X						1													
380 KEARNY AVE TODDLERS CLASSROOM SINK (630-86796-5)		5/22/24		07:40 Eastern		Drinking Water				X						1													
380 KEARNY AVE TODDLERS BR (630-86796-6)		5/22/24		07:42 Eastern		Drinking Water				X						1													
380 KEARNY AVE KITCHEN (630-86796-7)		5/22/24		07:45 Eastern		Drinking Water				X						1													
<p>Note: Since laboratory accreditations are subject to change, Eurofins Environment Testing Philadelphia, LLC places the ownership of method, analyte &amp; accreditation compliance upon our subcontract laboratories. This sample shipment is forwarded under chain-of-custody. If the laboratory does not currently maintain accreditation in the State of Origin listed above for analysis/tests/matrix being analyzed, the samples must be shipped back to the Eurofins Environment Testing Philadelphia, LLC laboratory or other instructions will be provided. Any changes to accreditation status should be brought to Eurofins Environment Testing Philadelphia, LLC attention immediately. If all requested accreditations are current to date, return the signed Chain of Custody attesting to said compliance to Eurofins Environment Testing Philadelphia, LLC.</p>																													
<b>Possible Hazard Identification</b>										<b>Sample Disposal ( A fee may be assessed if samples are retained longer than 1 month)</b>																			
Unconfirmed										<input type="checkbox"/> Return To Client <input type="checkbox"/> Disposal By Lab <input type="checkbox"/> Archive For _____ Months																			
Deliverable Requested: I, II, III, IV, Other (specify)					Primary Deliverable Rank: 1					Special Instructions/QC Requirements:																			
Empty Kit Relinquished by:					Date:					Time:					Method of Shipment:														
Relinquished by: <i>Andres Betancur</i>					Date/Time: <i>5/29/24 1600</i>					Company: <i>EETP</i>					Received by:					Date/Time:					Company:				
Relinquished by:					Date/Time:					Company:					Received by:					Date/Time:					Company:				
Relinquished by:					Date/Time:					Company:					Received by: <i>[Signature]</i>					Date/Time: <i>5/30/24 10:20</i>					Company: <i>BLLBT</i>				
Custody Seals Intact: <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					Custody Seal No.:					Cooler Temperature(s) °C and Other Remarks: <i>4.5°C R:5.8 C:5.9</i>																			

*NY*

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8